



ALL PIPING AND TANKS MUST BE THOROUGHLY CLEANED OF SOLVENTS, WATER, PIPE DOPE, AND OILS BEFORE SENSING CABLES ARE INSTALLED.

NOTE CONNECTOR ORIENTATION MALE CONNECTOR PINS MUST POINT TOWARD CONTROL PANEL

PROJECT NAME:  
UST  
AQUEOUS  
CHEMICAL  
DOUBLE CONTAINMENT

DESCRIPTION:  
TRACETEK  
AQUEOUS CHEMICAL  
WATER LEAK DETECTION  
SYSTEM TYPICAL DRAWING

ENGINEER:

SCALE: NONE DATE: 2 JUL 2003

DRAWN BY:  
R. WARREN



CALIFORNIA DETECTION SYSTEMS, INC.  
17155 Von Karman Avenue  
Suite 104  
Irvine, CA 92614-0906  
Phone — (949)223-9800  
Fax (949)223-9804