



# TRACETEK LEAK DETECTION SYSTEM

## COMMISSIONING RECORD

Company Owning or  
Operating Facility \_\_\_\_\_

Authorized TraceTek  
service representative \_\_\_\_\_

Building/unit \_\_\_\_\_

Address \_\_\_\_\_

Site Address \_\_\_\_\_

Street \_\_\_\_\_

Contact Person \_\_\_\_\_

Contact Person \_\_\_\_\_

Telephone \_\_\_\_\_ Email \_\_\_\_\_

Telephone \_\_\_\_\_ Email \_\_\_\_\_

### 1. GENERAL SYSTEM CONFIGURATION NOTES

#### Main Control Panel:

TT-TS12 model # \_\_\_\_\_ serial # \_\_\_\_\_  
 TTDM-128 \_\_\_\_\_ serial # \_\_\_\_\_  
 other \_\_\_\_\_

#### Sub Control Panel:

TTDM-128 \_\_\_\_\_ serial # \_\_\_\_\_

#### Quantity of External SIM/SIM type:

TTSIM-1 \_\_\_\_\_ TTSIM-1A \_\_\_\_\_ TTSIM-2 \_\_\_\_\_ Power \_\_\_\_\_

#### List other components (for example TT-NRM):

#### List Sensing cable/components:

#### Application Type:

- Beneath raised floor     Sump     Trench  
 Double contained piping     Buried pipeline  
 Around/Under tank     Overhead piping  
 Other: \_\_\_\_\_

### 2. TTDM-128 INSTALLATION INSPECTION

- Visual Inspection     Seating of circuit Boards

Wiring(Check All Applicable)	N/A	Wired	Verified
Ground/earth	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Power supply wiring	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Sensing cable	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Zener barrier	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Fault relay	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Leak relay	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Service relay	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4-20 mA	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
RS-232/485 Host Port	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
TT-NRM (Quantity: _____)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Internal SIM	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
RS-485 SIM Network port	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

### 3. TTDM-128 INITIAL POWER UP TEST

#### Close enclosure and supply power to the unit.

- Green LED illuminated at first  
 Passes self-tests  
 Finds all connected Network Modules, (TTSIM, TT-NRM, etc)

### 4. TTDM-128 GENERAL SETTINGS

- Language selected: \_\_\_\_\_  
 Affix front panel label in chosen language  
 Change time/date to local time  
 Set units  
 ft     m     zones

### 5. SELF TESTS WITH UI SOFTWARE

- UI Test     Audio Tests  
 Memory Tests     Display Test  
 SI Test     Keypad

Alert response personnel before testing relays or other interfaces (if connected):

- Relay Test  
 4-20 mA Test (if installed and connected)  
 Host port comm. Loop back test (requires transmit/receive jumper)

### 6. LEAK AND PORT SETTINGS

Leak	Default	Other
Re-alarm interval	<input type="checkbox"/> Never	<input type="checkbox"/> _____
Auto-Reset	<input type="checkbox"/> Off	<input type="checkbox"/> On
Audible Alarm	<input type="checkbox"/> On	<input type="checkbox"/> Off
Alarm re-flash	<input type="checkbox"/> Off	<input type="checkbox"/> On
Alarm Reset	<input type="checkbox"/> Single	<input type="checkbox"/> All
Host port		
Baud	<input type="checkbox"/> 9600	<input type="checkbox"/> _____
485 Address	<input type="checkbox"/> 1	<input type="checkbox"/> _____
Mode switch	<input type="checkbox"/> RS 232	<input type="checkbox"/> RS 485
TTDM	<input type="checkbox"/> Master	<input type="checkbox"/> Slave

### 7. SIM MODULE SETTINGS

After fully assembling the leak detection system including sensing cables/components, record SIM parameter values on Table 1 (use extra copies as necessary) for all commissioned SIM's.

### 8. RELAY CONFIGURATION

Complete this section for TTSIM-1A or TTSIM-2 modules, or when TT-NRMs are installed.

TT-NRM Regions and Relays:

#	Start	End	ID	Region Relay	Trouble Relay	Service Relay
1						
2						
3						
4						
5						
6						
7						
8						
9						
10						

SIM relay :

- Alarm mode  Leak  Leak/Break  
Alarm state  On  Off  
Alarm reset  Auto  Manual  Safe

### 9. SYSTEM MAP FOR ENTIRE LEAK DETECTION SYSTEM

Record leak location readings for simulated leaks created at key points on the circuit for each relevant SIM address number.

Record in Table 2, which also can be used to document configuration. Use extra copies as necessary.

This data can be used to prepare a graphical System Map, which is very desirable for customer utilization.

### SIGNATURES

Test performed by: Name \_\_\_\_\_ Signature \_\_\_\_\_ Date \_\_\_\_\_

Client acceptance: Name \_\_\_\_\_ Signature \_\_\_\_\_ Date \_\_\_\_\_

### 10. OPERATION AND MAINTENANCE TESTING

This documentation was provided and reviewed with the end user:

#### Project specific documents:

- \_\_\_\_\_
- \_\_\_\_\_
- \_\_\_\_\_
- \_\_\_\_\_
- \_\_\_\_\_

#### Installation instructions:

- \_\_\_\_\_
- \_\_\_\_\_

#### Sensor installation instructions:

- \_\_\_\_\_
- \_\_\_\_\_

### 11. ACCEPTANCE TEST

When sensor is subjected to a simulated leak

- System detects and locates simulated leak

Acceptance test was performed in presence of owner's representative:

- Yes  No

**TABLE 1 - SIM MODULE SETTINGS**

SIM Type \_\_\_\_\_  
 SIM Address \_\_\_\_\_  
 ID \_\_\_\_\_  
 Serial Number \_\_\_\_\_  
 Test length \_\_\_\_\_ ft / m / z  
 Sense Current \_\_\_\_\_  $\mu$ A  
 Service alert >= \_\_\_\_\_  $\mu$ A  
 Sense Resistance \_\_\_\_\_ K $\Omega$   
 Leak alarm <= \_\_\_\_\_ K $\Omega$   
 RG Resistance \_\_\_\_\_  $\Omega$   
 YB Resistance \_\_\_\_\_  $\Omega$   
 SI Version \_\_\_\_\_  
 SI Comm \_\_\_\_\_ %  
 Ground Fault Check \_\_\_\_\_

SIM Type \_\_\_\_\_  
 SIM Address \_\_\_\_\_  
 ID \_\_\_\_\_  
 Serial Number \_\_\_\_\_  
 Test length \_\_\_\_\_ ft / m / z  
 Sense Current \_\_\_\_\_  $\mu$ A  
 Service alert >= \_\_\_\_\_  $\mu$ A  
 Sense Resistance \_\_\_\_\_ K $\Omega$   
 Leak alarm <= \_\_\_\_\_ K $\Omega$   
 RG Resistance \_\_\_\_\_  $\Omega$   
 YB Resistance \_\_\_\_\_  $\Omega$   
 SI Version \_\_\_\_\_  
 SI Comm \_\_\_\_\_ %  
 Ground Fault Check \_\_\_\_\_

SIM Type \_\_\_\_\_  
 SIM Address \_\_\_\_\_  
 ID \_\_\_\_\_  
 Serial Number \_\_\_\_\_  
 Test length \_\_\_\_\_ ft / m / z  
 Sense Current \_\_\_\_\_  $\mu$ A  
 Service alert >= \_\_\_\_\_  $\mu$ A  
 Sense Resistance \_\_\_\_\_ K $\Omega$   
 Leak alarm <= \_\_\_\_\_ K $\Omega$   
 RG Resistance \_\_\_\_\_  $\Omega$   
 YB Resistance \_\_\_\_\_  $\Omega$   
 SI Version \_\_\_\_\_  
 SI Comm \_\_\_\_\_ %  
 Ground Fault Check \_\_\_\_\_

SIM Type \_\_\_\_\_  
 SIM Address \_\_\_\_\_  
 ID \_\_\_\_\_  
 Serial Number \_\_\_\_\_  
 Test length \_\_\_\_\_ ft / m / z  
 Sense Current \_\_\_\_\_  $\mu$ A  
 Service alert >= \_\_\_\_\_  $\mu$ A  
 Sense Resistance \_\_\_\_\_ K $\Omega$   
 Leak alarm <= \_\_\_\_\_ K $\Omega$   
 RG Resistance \_\_\_\_\_  $\Omega$   
 YB Resistance \_\_\_\_\_  $\Omega$   
 SI Version \_\_\_\_\_  
 SI Comm \_\_\_\_\_ %  
 Ground Fault Check \_\_\_\_\_

SIM Type \_\_\_\_\_  
 SIM Address \_\_\_\_\_  
 ID \_\_\_\_\_  
 Serial Number \_\_\_\_\_  
 Test length \_\_\_\_\_ ft / m / z  
 Sense Current \_\_\_\_\_  $\mu$ A  
 Service alert >= \_\_\_\_\_  $\mu$ A  
 Sense Resistance \_\_\_\_\_ K $\Omega$   
 Leak alarm <= \_\_\_\_\_ K $\Omega$   
 RG Resistance \_\_\_\_\_  $\Omega$   
 YB Resistance \_\_\_\_\_  $\Omega$   
 SI Version \_\_\_\_\_  
 SI Comm \_\_\_\_\_ %  
 Ground Fault Check \_\_\_\_\_

SIM Type \_\_\_\_\_  
 SIM Address \_\_\_\_\_  
 ID \_\_\_\_\_  
 Serial Number \_\_\_\_\_  
 Test length \_\_\_\_\_ ft / m / z  
 Sense Current \_\_\_\_\_  $\mu$ A  
 Service alert >= \_\_\_\_\_  $\mu$ A  
 Sense Resistance \_\_\_\_\_ K $\Omega$   
 Leak alarm <= \_\_\_\_\_ K $\Omega$   
 RG Resistance \_\_\_\_\_  $\Omega$   
 YB Resistance \_\_\_\_\_  $\Omega$   
 SI Version \_\_\_\_\_  
 SI Comm \_\_\_\_\_ %  
 Ground Fault Check \_\_\_\_\_

SIM Type \_\_\_\_\_  
 SIM Address \_\_\_\_\_  
 ID \_\_\_\_\_  
 Serial Number \_\_\_\_\_  
 Test length \_\_\_\_\_ ft / m / z  
 Sense Current \_\_\_\_\_  $\mu$ A  
 Service alert >= \_\_\_\_\_  $\mu$ A  
 Sense Resistance \_\_\_\_\_ K $\Omega$   
 Leak alarm <= \_\_\_\_\_ K $\Omega$   
 RG Resistance \_\_\_\_\_  $\Omega$   
 YB Resistance \_\_\_\_\_  $\Omega$   
 SI Version \_\_\_\_\_  
 SI Comm \_\_\_\_\_ %  
 Ground Fault Check \_\_\_\_\_

SIM Type \_\_\_\_\_  
 SIM Address \_\_\_\_\_  
 ID \_\_\_\_\_  
 Serial Number \_\_\_\_\_  
 Test length \_\_\_\_\_ ft / m / z  
 Sense Current \_\_\_\_\_  $\mu$ A  
 Service alert >= \_\_\_\_\_  $\mu$ A  
 Sense Resistance \_\_\_\_\_ K $\Omega$   
 Leak alarm <= \_\_\_\_\_ K $\Omega$   
 RG Resistance \_\_\_\_\_  $\Omega$   
 YB Resistance \_\_\_\_\_  $\Omega$   
 SI Version \_\_\_\_\_  
 SI Comm \_\_\_\_\_ %  
 Ground Fault Check \_\_\_\_\_

**TABLE 2 - LEAK DETECTION SYSTEM MAP INFORMATION**

Master Control Panel \_\_\_\_\_

Sub Control Panel \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

SIM Address No.	Circuit Name/ID	Leak Sensor Type	Simulated Leak Location Description	Reported Leak Distance



WWW.PENTAIRTHERMAL.COM

**NORTH AMERICA**  
 Tel: +1.800.545.6258  
 Fax: +1.800.527.5703  
 Tel: +1.650.216.1526  
 Fax: +1.650.474.7215  
 thermal.info@pentair.com

**EUROPE, MIDDLE EAST, AFRICA**  
 Tel: +32.16.213.511  
 Fax: +32.16.213.603  
 thermal.info@pentair.com

**ASIA PACIFIC**  
 Tel: +86.21.2412.1688  
 Fax: +86.21.5426.2917  
 cn.thermal.info@pentair.com

**LATIN AMERICA**  
 Tel: +1.713.868.4800  
 Fax: +1.713.868.2333  
 thermal.info@pentair.com

Pentair and TraceTek are owned by Pentair or its global affiliates. All other trademarks are the property of their respective owners. Pentair reserves the right to change specifications without prior notice.

© 1996-2014 Pentair.