



- LEGEND
- TRAY CABLE
 - TT3000 CABLE
 - TT-MET-MC
 - TT-MBC-MC
 - TT-PFT-MC

PROJECT NAME:
 UST AQUEOUS
 DOUBLE CONTAINMENT
 UNATTENDED SYSTEM
 NON-LOCATING PANEL

DESCRIPTION:
 TRACETEK
 AQUEOUS CHEMICAL
 LEAK DETECTION SYSTEM
 TYPICAL DRAWING

ENGINEER:

SCALE: NONE	DATE: 2 JUL 2003
----------------	---------------------

DRAWN BY:
 R. WARREN



CALIFORNIA DETECTION
 SYSTEMS, INC.
 17155 Von Karman Avenue
 Suite 104
 Irvine, CA 92614-0906
 — Phone —
 (949)223-9800
 Fax (949)223-9804

ALL PIPING AND TANKS MUST BE THOROUGHLY CLEANED OF SOLVENTS, WATER, PIPE DOPE, AND OILS BEFORE SENSING CABLES ARE INSTALLED.

NOTE CONNECTOR ORIENTATION MALE CONNECTOR PINS MUST POINT TOWARD CONTROL PANEL