



ALL PIPING AND TANKS MUST BE THOROUGHLY CLEANED OF SOLVENTS, WATER, PIPE DOPE, AND OILS BEFORE SENSING CABLES ARE INSTALLED.

NOTE CONNECTOR ORIENTATION
MALE CONNECTOR PINS MUST POINT TOWARD CONTROL PANEL

PROJECT NAME:
UST
HYDROCARBON
CHEMICAL
DOUBLE CONTAINMENT

DESCRIPTION:
TRACETEK
HYDROCARBON CHEMICAL/
WATER LEAK DETECTION
SYSTEM TYPICAL DRAWING

ENGINEER:

SCALE: NONE DATE: 2 JUL 2003

DRAWN BY:

R. WARREN



CALIFORNIA DETECTION
SYSTEMS, INC.
17155 Von Karman Avenue
Suite 104
Irvine, CA 92614-0906

Phone —
(949)223-9800
Fax (949)223-9804