



Jeb Bush
Governor

Department of Environmental Protection

Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

David B. Struhs
Secretary

December 26, 2002

Certified Mail

Return Receipt Requested: 7001 0320 0001 7977 1090

Mr. Terry Warren
Tyco Thermal Controls
2941 Kate Bond Blvd. Suite 101
Bartlett, TN 38133

RE: DEP Approval of the TraceTek TT5000 leak detection system for single-walled underground bulk product piping
File No. EQ-551

Dear Mr. Warren:

The Bureau of Petroleum Storage Systems has concluded its review of the Equipment Approval requests dated December 5, December 12, and December 13, 2002, which were submitted for the above referenced equipment pursuant to Rule 62.761.850, Florida Administrative Code (F.A.C.).

"...the TraceTek TT5000 leak detection system for single-walled underground bulk product piping will provide environmental protection substantially equivalent to that provided by compliance with the requirements established in Rules..."

detection of single-walled bulk product piping performed in accordance with Exhibit A. A copy of this order shall be distributed to any facility that uses this product. A copy of the annual operability test shall be given to any tank owner purchasing or using this system in the state of Florida.

Please be advised that the above referenced DEP rules are subject to change. If the above rule standards are modified in the future, this order may be modified or rescinded for future upgrades and installations. Additionally, if it is later determined that the above referenced product(s) do not meet the appropriate performance standards or show a consistent pattern of failure(s), and therefore does not provide substantially equivalent environmental protection, the Department may rescind this order.